

TO BE TAPED PER MFR'S
RECOMMENDATIONS

1/2" GYP. BOARD ON ALL
WALLS & CEILINGS

2 X 4 STUDS @ 16" O.C.
WITH R-13 BATT INSUL.,
PROVIDE VAPOR BARRIER
BETWEEN GYP. BOARD & STUD
@ ALL EXTERIOR WALLS

1/2" PLYWOOD OR O.S.B.

3/4" TONGUE & GROOVE PLYWOOD,
GLUE & NAIL TO FLOOR JOIST

2 X 10 AS NOTED
BRIDGINS @ 8'-0" O.C., TYPICAL

2 X 6 STUDS @ 16" O.C.
WITH R-19 BATT INSUL.,
PROVIDE VAPOR BARRIER
BETWEEN GYP. BOARD & STUD
@ ALL EXTERIOR WALLS

4" 4000 PSI CONC. SLAB
WITH 6 X 6 X 10/10 W.W.F.
& 6 MIL. POLYETHYLENE
VAPOR BARRIER OVER 4" MIN.
COMPACTED GRANULAR FILL

2 X 10 PL., SILL SEALER BETWEEN
ALL FL'S & MASONRY, 1/2" Ø
ANCHOR BOLTS EMBEDDED 15"
MIN. @ 6'-0" O.C. (AT LEAST 2
A. B. PER PIECE)

FINISH GRADE

ALL NATURAL WASHED GRAVEL
AT MIN. TO LOCAL CODE
FILL BLOCK CORES W/ FOAM INSUL.

4" DRAIN TILE CONTINUOUS

1'-8"

3'-6" MIN.
BELOW GRADE

6'-10" TOP/WINDOW

8'-5 1/2"

6'-10" TOP/WINDOW

1 X 3 BRID

8'-8" (13 COURSE)

TYP. ONE STORY WALK OUT WALL SECTION 3/4"