

CONSTRUCTION ENTRANCE

SPECIFICATIONS FOR CONSTRUCTION ENTRANCE:

- 1. STONE SIZE-ODOT #2 (1.5-2.5 INCH) STONE SHALL BE USED, OR RECYCLED CONCRETE EQUIVALENT.
- LENGTH——THE CONSTRUCTION ENTRANCE SHALL BE AS LONG AS REQUIRED TO STABILIZE HIGH TRAFFIC AREAS BUT NOT LESS THAN 70 FT. (EXCEPT ON SINGLE RESIDENCE LOT WHERE A 30-FT. MINIMUM LENGTH APPLIES).
- THICKNESS——THE STONE LAYER SHALL BE AT LEAST 6 IN. THICK FOR LIGHT DUTY ENTRANCES OR AT LEAST 10 INCHES FOR HEAVY DUTY USE.
- WDTH---THE ENTRANCE SHALL BE AT LEAST 14 FT. MIDE, BUT NOT LESS THAN THE FUEL WIDTH AT POINTS WHERE INGRESS AND EGRESS OCCURS.
- GEOTEXTILE--A GEOTEXTILE SHALL BE PLACED OVER THE ENTIRE AREA PRIOR TO PLACING STONE. IT SHALL BE COMPOSED OF STHONG ROT-PROOF POLYMERIC FIBERS AND MEET THE FOLLOWING SPECS.

GEOTEXTILE SPECIFICATION FOR	CONSTRUCTION ENTRANCE
MINIMUM TENSILE STRENGTH	200 LBS.
MINIMUM PUNCTURE STRENGTH	80 PSi
MINIMUM TEAR STRENGTH	50 LBS.
MINIMUM BURST STRENGTH	320 PSI
MINIMUM ELONGATION	20%
Equivalent opening size	EOS < 0.6 MM.
PERMITTINTY	1 X 10-3 CM/SEC.

- 6. TIMING THE CONSTRUCTION ENTRANCE SHALL BE INSTALLED AS SOON AS IS PRACTICABLE SEFORE MAJOR GRADING ACTIVITIES.
- CULVERT—A PIPE OR CULVERT SHALL BE CONSTRUCTED UNDER THE ENTRANCE IF NEEDED TO
 PREVENT SURFACE WATER FLOWING ACROSS THE ENTRANCE FROM BEING DIRECTED OUT ONTO
 PAVED SURFACES.
- 8. WATER BAR--A WATER BAR SHALL BE CONSTRUCTED AS PART OF THE CONSTRUCTION ENTRANCE IF NEEDED TO PREVENT SURFACE RUNOFF FROM FLOWING THE LENGTH OF THE CONSTRUCTION ENTRANCE AND OUT ONTO PAVED SURFACES.

DESCRIPTION:

A construction entrance is a stabilized pad of acgregate over a ceotextile base and is used to reduce the amount of mud tracked off—site with construction traffic.

CONDITIONS WHERE PRACTICE APPLIES:

- A CONSTRUCTION ENTRANCE SHOULD BE USED:
- WHERE CONSTRUCTION VEHICLES LEAVE ACTIVE CONSTRUCTION AREAS ONTO SURFACES WHERE RUNOFF IS NOT CHECKED BY SEDIMENT CONTROLS;
- * AT ALL POINTS OF EGRESS TO PUBLIC ROADS;
- * WHERE FREQUENT VEHICLES AND EQUIPMENT INGRESS/EGRESS IS EXPECTED SUCH AS AT THE ENTRANCE OF INDIVIDUAL BUILDING LOTS;

PLANNING CONSIDERATIONS:

THIS PRACTICE SHOULD NOT BE RELIED ON TO REMOVE MUD FROM CONSTRUCTION TRAFFIC. MOST MUD-IS FLUING FROM TIRES AS VEHICLES REACH SPEEDS HIGHER THAN IS REACHED ON SITE. THE BEST APPROACH TO PREVENTING OFF-SITE TRACKING IS TO KEEP VEHICLES THAT FREQUENTLY ENTER AND LEAVE A SITE, AWAY FROM MUDDY AREAS IN THE FIRST PLACE. VEHICLES SHOULD BE RESTRICTED TO STABILIZED AREAS TO THE EXTENT PRACTICAL, AND AREAS WHERE FREQUENT INGRESS/EGRESS IS EXPECTED SHOULD BE STABILIZED.

- 9, MAINTENANCE—TOP DRESSING OF ADDITIONAL STONE SHALL BE APPLIED AS CONDITIONS DEMAND, MUD SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC ROADS, OR ANY SURFACE WHERE RUNOFF IS NOT CHECKED BY SEDIMENT CONTROLS, SHALL BE REMOVED IMMEDIATELY. REMOVAL SHALL BE ACCOMPLISHED BY SCRAPING OR SWEEPING.
- 10. CONTRUCTION ENTRANCES SHALL NOT BE RELIED UPON TO REMOVE MUD FROM VEHICLES AND PREVENT OFF—SITE TRACKING. VEHICLES THAT ENTER AND LEAVE THE CONSTRUCTION—SITE SHALL BE RESTRICTED FROM MUDDLY AREAS.
- ti. Removal-- The entrance shall remain in place until the disturbed area is stabilized or replaced

<u>LEGEND</u> O = IRON PIN FND (= IRON PIN SET = MONUMENT BOX S = SANITARY MANHOLE 1 = STORM MANHOLE M= WATER VALVE A FIRE HYDRANT = CURB INLET \$\phi = LIGHT POLE = OFFSET HUB = TELEPHONE PEDESTAL E = ELECTRIC BOX = CABLE PEDESTAL FLOW DIRECTION SWALE -~ = INLET PROTECTION EXISTING GRADE PROPOSED GRADE

○ = PROP SILT FENCE

		5425 WARNER ROAD - SUITE 12 VALLEY VIEW, OHIO 44125	SITE DETAILS			
HORIZ. SCALE:	VERT. SCÄLE:	440-602-9071 FAX 216-369-0259	K. HOVINANIAN OSTER HOMES LLC.			
	DATE 5/30/2014		8280 CAMBDEN CROSSING WAY	H		
DRAWN BY. CL	DATE: Sy Oby 2017	TECH	S/L 35 IN THE CAMBDEN CREEK ESTATES PHASE NO.2			
CHECKED BY SRL	DRAWING NO.: 20112519		PLAT VOLUME 60. PAGE 15		1	
JOB NO. 20112519	SHEET: 3 OF 3	ENGINEERING + SURVEYING Civil Engineering + Land Surveying	بحرور ويمنى مرينسية ويواد ويمرون مسروري ورا	NO.	DATE	DESCRIPTION BY