

NOTES :

1. CONTRACTOR SHALL VERIFY LOCATION AND DEPTH OF ALL UTILITIES PRIOR TO CONSTRUCTION.
2. LAKE COUNTY HEALTH DISTRICT RULES AND STANDARDS ARE TO BE USED.
3. THE AERATION UNIT SHALL HAVE A 500 GPD CAPACITY, NSF 40 CLASS I RATING, FAIL SAFE WIRING AND AN AUDIBLE ALARM.
4. EROSION CONTROL METHODS SHALL BE USED WHERE NEEDED AND FOLLOW THE LAKE COUNTY SOIL AND WATER DISTRICT REQUIREMENTS.

