

CERTIFICATION :

"I CERTIFY THIS SEWAGE SYSTEM DESIGN MEETS THE MINIMUM REQUIREMENTS ESTABLISHED BY THE LCGHD IN THE HSTS - GUIDANCE MANUAL, AND THE DISTRIBUTION AREA HAS BEEN FIELD VERIFIED AND PROTECTED WITH MARKING TAPE. SYSTEM MANUFACTURER

DAVID W. NOVAK, P.S. No. 7507

Plans submitted to LCGHD and meet design criteria
Hydraulic calculations verified and accurate

DRAIN DISTRIBUTION PLAN SUBMITTAL REVIEW

Date

Name

9-21-04

David B. Norris, P.E.

9-14-04

David B. Norris, P.E.

9-15-04

Joseph K. [unclear]

20162 SQ. FT.
0.4629 ACRES

N 00°03'03" E 83.00'

PIN SET

N 89°56'26" E 243.00'

20' LOCAL SERVICE DRAINAGE EASEMENT

4
20176 SQ. FT.
0.4632 ACRES

DUPLICATION AREA

CONTROL UNIT

2,000 GAL. SEPTIC TANK

2,000 GAL. BOSE TANK

DRAIN TUBING- 2 ZONES WITH 8 I. PIN SET LATERALS IN EACH ZONE. EACH LATERAL WILL HAVE TO RUNS OF 119 FT. EACH. TOTAL OF 953 LF. PER ZONE

S 89°56'26" W 243.16'

3
20189 SQ. FT.
0.4635 ACRES

HYDRAULIC UNIT

I. PIN SET

BELLMORE RD. 60'

Stormwater Management Plan
Approved as shown and/or noted
JAMES R. GILLS, III
County Drainage Engineer

By [signature] Date 9/24/04

GENERAL NOTES:

1. BENCHMARK - TOP STEM OF EXISTING FIRE HYDRANT LOCATED IN FRONT SUBLOT 22, ELEVATION = 700.31.
2. DRIVEWAY APRON TO BE 6" THICK CONCRETE.
3. ALL DOWNSPOUTS TO BE OUTLETED TO SPLASH BLOCKS.
4. CONTRACTOR RESPONSIBLE FOR CONTACTING THE OHIO UTILITY PROTECTION SERVICE (1.800.362.2764) AND ALL UTILITY COMPANIES A MINIMUM OF 48 HOURS PRIOR TO CONSTRUCTION.
5. THE LOCATION BOTH HORIZONTAL AND VERTICAL OF EXISTING UNDERGROUND UTILITIES SHOWN HEREON, HAVE BEEN OBTAINED BY A DILIGENT AND COMPREHENSIVE SEARCH OF AVAILABLE RECORDS. VERIFICATION BY FIELD OBSERVATION HAS BEEN CONDUCTED WHERE PRACTICAL, HOWEVER, BARRINGTON CONSULTING GROUP, INC. DOES NOT GUARANTEE THE COMPLETENESS, NOR ACCURACY THEREOF.
6. CONTRACTOR SHALL VERIFY ELEVATIONS OF LATERAL INVERTS IN THE FIELD PRIOR TO FOUNDATION EXCAVATION.
7. SEE SHEET 2 FOR EROSION AND SEDIMENT-CONTROL PLAN
8. SEE SHEET 2 FOR SEEDING INFORMATION

CERTIFICATION :

"I THE UNDERSIGNED HEREBY CERTIFIES THAT THIS TOPOGRAPHY INDICATED BY 1 FOOT CONTOURS AND ELEVATION SHOWN HEREON REPRESENTS AN ACTUAL SURVEY MADE BY ME ON THE 16th DAY OF JANUARY, 2002 AND THE ELEVATIONS WERE TAKEN AT AN APPROPRIATE INTERVAL AND AS OF THAT DAY THEY EXISTED AS INDICATED HEREON.

"I HEREBY CERTIFY THAT THIS PLAN WAS PREPARED BY ME AND IS CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF"

DAVID W. NOVAK, P.S. No. 7507

CERT-1.DWG

GRAPHIC SCALE



Barrington
CONSULTING GROUP, INC.
38342 WESTERN PARKWAY, SUITE 10
WILLOUGHBY, OHIO 44094
PHONE 440.946.1761 FAX 440.918.0486



SITE PLAN
SUBLOT 04, BELLMORE ROAD, PAINESVILLE TWP.
BELLMORE SUBDIVISION
LITTLE MOUNTAIN HOMES, INC.

DESIGNED WSO	CHECKED DWN
DATE AUG. 06, 2004	SCALE 1" = 30'
JOB NO. 02007-04	SHEET 1/5

OF SHEETS