

SITE PLAN

FOR
WARREN CONNALLY

BEING PART OF LOTS 12 & 13 TRACT 1,
TOWNSHIP OF PAINESVILLE, COUNTY
OF LAKE STATE OF OHIO

MORGAN & HALLIE PEPPER
Vol. 602-308

1" = 20'

EXIST.
PROP.

EXIST.
PROP.

PAINESVILLE TWP. LOCAL SCHOOLS
[VACANT LAND]
PLAYGROUND

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date: 3-28-89
JOEL LUCIA, R. S., M. P. H.
Health Commissioner
BY: *Joel Lucia*

- A. To be brought to finished grade
1. Septic tank manhole covers
 2. Splitter box cover
 3. Distribution box cover
- B. No footer drains or downspouts
to be discharged into septic tanks
C. All waste water to be discharged into
septic tanks

HYDRAULIC PROFILE
VERT. 1" = 4' HORIZ. 1" = 20'

DAVID R. SCANT
Vol. 338-208

LOW YIELD WATER
FIXTURES REQUIRED
ON ALL:
Shower Head
Toilet

SEWAGE DISPOSAL PERMIT MUST BE
OBTAINED BY A LAKE COUNTY LICENSED
INSTALLER BEFORE INSTALLATION IS
STARTED.

44711 Bldg. Dept.

Grading Plan Approved
as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By: *TLG* Date: 3-28-89

This Permit Expires
3-23-90

PAINESVILLE TOWNSHIP
ZONING APPROVED
7791

William E. McLaughlin
Zoning Inspector 3/23/89

THIS PLAN WAS PREPARED BY ME AND IS
ACCURATE TO THE BEST OF MY KNOWLEDGE
AND BELIEF.

Thomas M. Coffey, P.E.

