

EROSION CONTROL DETAILS

Foresight Engineering Group

Engineers & Surveyors

440 286-1010
440 286-1034 fax
320 Center Street, Unit F
Chardon, Ohio 44024

SCALE : NONE

Page: 2/2

Specifications for Small Lot Building Sites

- 1 Pressuring vegetation shall be retained on idle portions of the building lot for as long as construction operations allow. Clearing shall be done so only areas where areas are bare.
- 2 Soil lenses shall control sheet flow runoff from the building lot. It shall not be concentrated in channels or areas of concentrated flow. Other sediment controls such as inlet protection and sediment traps shall also be used as needed to control sediment runoff.
- 3 Construction vehicle access shall be limited to one route, to the greatest extent practical. The access shall be gravel or crushed rock applied to the driveway area.
- 4 Barriers shall control sheet flow runoff from the building lot. It shall not be concentrated in channels or areas of concentrated flow. Other sediment controls such as inlet protection and sediment traps shall also be used as needed to control sediment runoff.

Specifications for Temporary Seeding

Temporary Seeding Species Selection			
Seeding Dates	Species	Lb / 1,000 ft ²	Per Acre
March 1 to August 15	Oats	3	4 bushel
	Tall Fescue	1	40 lb
	Annual Ryegrass	1	40 lb
	Perennial Ryegrass	1	40 lb
	Tall Fescue	1	40 lb
	Annual Ryegrass	1	40 lb
August 16 to November 1	Rye	3	2 bushel
	Tall Fescue	1	40 lb
	Annual Ryegrass	1	40 lb
	Wheat	3	2 bushel
	Tall Fescue	1	40 lb
	Annual Ryegrass	1	40 lb
November 1 to Spring Seeding	Use mulch only, seeding practices or dormant seeding		

Note: Other approved seed species may be substituted.

sq. ft. (two to three times). The mulch shall be spread uniformly by hand or mechanically so the soil surface is covered. For uniform distribution of hand-spread mulch, divide area into approximately 1,000-sq.-ft. sections and spread two 45-lb bags of straw in each section.

Hydroseeds—If wood cellulose fiber is used, it shall be used at 2,000 lb / ac or 40 lb / 1,000 sq. ft.

Other—Other acceptable mulches include mulch matting applied according to manufacturer's recommendations or wood chips applied at 8 tons / ac.

Mulch shall be anchored immediately to minimize loss by wind or water.

Mechanical—A disk, compactor, or similar type tool shall be set straight to punch or anchor the mulch material into the soil. Straw mechanically anchored shall not be finely chopped but, generally, be left longer than 6 in.

Mulch Netting—Netting shall be used according to the manufacturer's recommendations. Netting may be necessary to hold mulch in place in areas of concentrated runoff and on critical slopes.

Asphalt Emulsion—Asphalt shall be applied as recommended by the manufacturer or at the rate of 100 gal / ac.

Synthetic Binders—Synthetic binders such as Acrylic DLN (Agn-Tac), DCA-70, Petroset, Terra Tac or equal may be used at rates recommended by the manufacturer.

Wood Cellulose Fiber—Wood cellulose fiber binder shall be applied at a net dry weight of 750 lb / ac. The wood cellulose fiber shall be mixed with water and the mixture shall contain a maximum of 50 lb / 100 gal of wood cellulose fiber.

Structural erosion and sediment control practices such as diversions and sediment traps shall be installed and stabilized with temporary seeding prior to grading the rest of the construction site.

Temporary seed shall be applied between construction operations on soil that will not be graded or reworked for 45 days or more. These idle areas should be seeded as soon as possible after grading or shall be seeded within 7 days. Several applications of temporary seeding are necessary on typical construction projects.

Hydroseeds—if wood cellulose fiber is used, it shall be used at 2,000 lb / ac or 40 lb / 1,000 sq. ft.

Other—Other acceptable mulches include mulch matting applied according to manufacturer's recommendations or wood chips applied at 8 tons / ac.

Mulch shall be anchored immediately to minimize loss by wind or water. Anchoring Methods

Mechanical—A disk, compactor, or similar type tool shall be set straight to punch or anchor the mulch material into the soil. Straw mechanically anchored shall not be finely chopped but, generally, be left longer than 6 in.

Mulch Netting—Netting shall be used according to the manufacturer's recommendations. Netting may be necessary to hold mulch in place in areas of concentrated runoff and on critical slopes.

Asphalt Emulsion—Asphalt shall be applied as recommended by the manufacturer or at the rate of 100 gal / ac.

Synthetic Binders—Synthetic binders such as Acrylic DLN (Agn-Tac), DCA-70, Petroset, Terra Tac or equal may be used at rates recommended by the manufacturer.

Wood Cellulose Fiber—Wood cellulose fiber binder shall be applied at a net dry weight of 750 lb / ac. The wood cellulose fiber shall be mixed with water and the mixture shall contain a maximum of 50 lb / 100 gal of wood cellulose fiber.

DORMANT SEEDING

- 1 Seedings shall not be planted from October 1 through November 20. During this period the seeds are likely to germinate but probably will not be able to survive the winter.
- 2 The following methods may be used for "Dormant Seeding":
 - From October 1 through November 20, prepare the seedbed, add the required amounts of lime and fertilizer, then mulch and anchor. After November 20, and before March 15, broadcast the selected seed mixture, increase the seeding rates by 50% for this type of seeding.
 - From November 20 through March 15, when conditions permit, prepare the seedbed, add lime and fertilizer, apply the selected seed mixture, mulch and anchor. Increase the seeding rates by 50% for this type of seeding.
 - Apply seed uniformly with a cyclone seeder, drill, cultipacker seeder, or hydro-seeder (stirrup may include seed and fertilizer) on a firm, moist seedbed.
- 3 Irrigation rates shall be avoided and irrigation monitored to prevent erosion and damage from runoff.

IRRIGATION

- 1 Permanent seeding shall include irrigation to establish vegetation during dry or hot weather or on adverse site conditions as needed for adequate moisture for seed germination and plant growth.
- 2 Excessive irrigation rates shall be avoided and irrigation monitored to prevent erosion and damage from runoff.

PERMANENT SEEDING

Seed Mix.	Seeding Rate		Notes
	lb / ac	lb / 1,000 ft ²	
General Use			
Cooling Red Fescue	20-40	1/1	
Dwarf Ryegrass	10-20	1/2	
Kentucky Bluegrass	10-20	1/2	
Tall Fescue	40	1	
Dwarf Poa	40	1	
Steep Banks or Cut Slopes			
Tall Fescue	40	1	
Crown Vetch	10	1	
Tall Fescue	20	1	Do not seed later than August
Poa	20	1	
Tall Fescue	20	1	Do not seed later than August
Road Ditches and Driveways			
Tall Fescue	40	1	
Dwarf Poa	50	2%	
Kentucky Bluegrass	5	1%	
Lawns			
Kentucky Bluegrass	60	1%	
Perennial Ryegrass	60	1%	
Kentucky Bluegrass	60	1%	
Cooling Red Fescue	60	1%	For shaded areas

Note: Other approved seed species may be substituted.

SPECIFICATIONS FOR PERMANENT SEEDING

- 1 Where feasible, except when a cultipacker type seeder is used, the seedbed should be formed following seeding operations with a cultipacker, roller, or light drag. On sloping land, seeding operations should be on the contour where feasible.
- 2 Mulch material shall be applied immediately after seeding. Seedings made during optimum seeding dates and with favorable soil conditions and on very flat areas may not need mulch to achieve adequate stabilization.
- 3 Root shall be applied where needed to establish vegetation.
- 4 Materials

- Straw—If straw is used it shall be unrooted small-grain straw applied at the rate of 2 tons / ac or 80 lb / 1,000 sq. ft. (two to three times). The straw shall be spread uniformly by hand or mechanically so the soil surface is covered. For uniform distribution of hand-spread straw, divide area into approximately 1,000-sq.-ft. sections and spread two 45-lb bags of straw in each section.
- Fertilizer—Fertilizer shall be applied as recommended by a soil test. Lime shall be applied at a rate of 100 lb / 1,000 sq. ft. or 2 tonnes.
- Mulch shall be worked into the soil with a disk, harrow, spring-tine harrow, or other suitable field implement to a depth of 3 in. On sloping land the soil shall be worked on the contour.
- Lime and fertilizer shall be worked into the soil with a disk, harrow, spring-tine harrow, or other suitable field implement to a depth of 3 in. On sloping land the soil shall be worked on the contour.
- Hydroseeds—If wood cellulose fiber is used, it shall be used at 2,000 lb / ac or 40 lb / 1,000 sq. ft.
- Other—Other acceptable mulches include mulch matting applied according to manufacturer's recommendations or wood chips applied at 8 tons / ac.

SEEDING DATES AND SOIL CONDITIONS

Seeding should be done March 1 to May 31 or Aug 1 to September 30. These seeding dates are ideal but, with the use of additional mulch and irrigation, seedings may be made any time throughout the growing season. Tillage/seeding preparation should be done when the soil is dry enough to crumble and not form ridges when compressed by hand. For winter seeding, see the following section on dormant seeding.

DORMANT SEEDING

- 1 Seedings shall not be planted from October 1 through November 20. During this period the seeds are likely to germinate but probably will not be able to survive the winter.
- 2 The following methods may be used for "Dormant Seeding":
 - From October 1 through November 20, prepare the seedbed, add the required amounts of lime and fertilizer, then mulch and anchor. After November 20, and before March 15, broadcast the selected seed mixture, increase the seeding rates by 50% for this type of seeding.
 - From November 20 through March 15, when conditions permit, prepare the seedbed, add lime and fertilizer, apply the selected seed mixture, mulch and anchor. Increase the seeding rates by 50% for this type of seeding.
 - Apply seed uniformly with a cyclone seeder, drill, cultipacker seeder, or hydro-seeder (stirrup may include seed and fertilizer) on a firm, moist seedbed.

IRRIGATION

- 1 Permanent seeding shall include irrigation to establish vegetation during dry or hot weather or on adverse site conditions as needed for adequate moisture for seed germination and plant growth.
- 2 Excessive irrigation rates shall be avoided and irrigation monitored to prevent erosion and damage from runoff.

PERMANENT SEEDING

Seed Mix.	Seeding Rate		Notes
	lb / ac	lb / 1,000 ft ²	
General Use			
Cooling Red Fescue	20-40	1/1	
Dwarf Ryegrass	10-20	1/2	
Kentucky Bluegrass	10-20	1/2	
Tall Fescue	40	1	
Dwarf Poa	40	1	
Steep Banks or Cut Slopes			
Tall Fescue	40	1	
Crown Vetch	10	1	
Tall Fescue	20	1	Do not seed later than August
Poa	20	1	
Tall Fescue	20	1	Do not seed later than August
Road Ditches and Driveways			
Tall Fescue	40	1	
Dwarf Poa	50	2%	
Kentucky Bluegrass	5	1%	
Lawns			
Kentucky Bluegrass	60	1%	
Perennial Ryegrass	60	1%	
Kentucky Bluegrass	60	1%	
Cooling Red Fescue	60	1%	For shaded areas

Note: Other approved seed species may be substituted.

SPECIFICATIONS FOR CURB INLET PROTECTION

- 1 A cultipacker, plow or other implement shall be used to reduce soil compaction and allow maximum infiltration. (Maximum infiltration will help control both runoff rate and water quality.) Subsoiling should be done when the soil moisture is low enough to allow the soil to crack or fracture. Subsoiling shall not be done on slope-prone areas where soil preparation should be limited to what is necessary for establishing vegetation.
- 2 The site shall be graded as needed to permit the use of conventional equipment for seedbed preparation and seeding.
- 3 Root shall be applied where needed to establish vegetation.
- 4 Materials

- Geotextile—Geotextile Over Non-Mesh Decking
- Compact Backfill Around Metal
- Geotextile—Geotextile Mesh Flat Against Curb
- Metal and Geotextile Mesh Flat Against Curb
- Filter Screen
- Flow
- Thickness

CURB INLET PROTECTION

- 1 Inlet protection shall be constructed either before up-to-date land disturbance begins or before the storm drain becomes operational.
- 2 The earth around the inlet shall be excavated completely to a depth of at least 18 in.
- 3 The wooden frame shall be constructed of 2-by-4-in. construction-grade lumber. The 2-by-4-in. pieces shall be driven 1 ft into the ground at four corners of the inlet and the top person of 2-by-4-in. frame assembled using the overlap joint shown. The top of the frame shall be at least 6 in below adjacent roads if ponded water would pose a safety hazard to traffic.
- 4 Wire mesh shall be applied as a continuous piece