* ALL PARCELS:
TERRY & GRETCHEN SINES
VOL. 196-398

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date 7-17-87
JOEL LUCIA, R. S., M. P. H.
Health Commissioner
BY Gerald B Mowrey

(VACANT)

PARCEL 3
0.688 Ac.

DUPLICATION AREA

S 86° 41' 40" E 300.00'

N 3° 30' E 100.00'

N 86° 41' 40" W 300.00'

PARCEL 2

CALL ROAD 60'

S 3° 30' W 100.00'

1751.40 TO ℄ DAVIS ROAD

18' MACADAM

24000 GAL. SEPTICS

SPLITTER

DIST. BOXES

60 75 L.F.

1 STY SLAB FF-99.00

75' SB NTS

WATER CONN.

16' DRIVE

1 STY SLAB FF-100.15

PROP. 8" WATER LINE

R/W

℄

HYDRAULIC PROFILE
VERT- 1" = 3' HORZ- 1" = 30'

EXIST

PROP

FF-99.00

LOW YIELD WATER FIXTURES REQUIRED ON ALL:
Shower Head
Toilet

STATE OF OHIO
THOMAS MARC COFFMAN
6857
REGISTERED SURVEYOR

N

PROP.
EXIST

By [signature] Date 7-17-87

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

SITE PLAN FOR TERRY SINES

BEING PART OF LOT 64, VILLAGE OF PERRY, COUNTY OF LAKE, STATE OF OHIO

Carol Heffner
Perry Village Zoning

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover
4. Vent Pipes

B. No footer drains or downspouts to be discharged into septic tanks

C. All waste water to be discharged into septic tanks

REVISED 7/14/87