



DUAL 2000 GALLON SEPTIC TANK

NOTES:

1. REINFORCED PRECAST CONCRETE SHALL HAVE A COMPRESSIVE STRENGTH OF 5000 PSI @ 28 DAYS.
2. 'POLYLOK' SEALS SHALL BE PROVIDED FOR INLET AND OUTLET CONNECTIONS. SEALS CAN BE USED FOR EITHER 3" OR 4" DIA. PIPE.

SANITARY CONSTRUCTION NOTES:

1. ALL GRAVITY SEWER LINES SHALL BE SCH. 40 PVC, 1/8"/FT. MIN., 1/4"/FT. MAX. SLOPE (Or As Shown On Plans) AND SHALL CONFORM TO ASTM D-3034 WITH JOINTS CONFORMING TO ASTM D-3212.
2. THESE DRAWINGS WERE PREPARED IN ACCORDANCE WITH THE OHIO DEPARTMENT OF HEALTH AND LAKE COUNTY GEERAL HEALTH DISTRICT REGULATIONS.
3. INSTALLER IS TO FIELD VERIFY GRADES AND CONSULT THE ENGINEER IN THE CASE OF DISCREPANCY.
4. ALL DISTURBED AREAS SHALL BE GRADED AND SEEDED UPON COMPLETION.
5. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL DEWATERING, SHEETING AND SHORING FOR EXCAVATION.
6. TANKS SHALL BE FILLED WITH WATER IMMEDIATELY AFTER INSTALLATION TO PREVENT 'FLOATING'.
7. ROOF DRAINS, FOUNDATION DRAINS, AND ALL OTHER CLEAN WATER CONNECTIONS TO THE SANITARY SYSTEM ARE PROHIBITED.

INSTALLATION:

INSTALLER SHALL CONTACT DESIGN ENGINEER 72 HOURS PRIOR TO START OF CONSTRUCTION. INSTALLER SHALL CONTACT DESIGN ENGINEER IN THE EVENT THAT ANY PORTION OF THE SYSTEM IS CHANGED DUE TO SITE CONDITIONS. DESIGN ENGINEER SHALL APPROVE OF ANY CHANGES. IN THE EVENT THAT CHANGES ARE MADE WITHOUT CONSULTATION WITH THE DESIGNER, THE INSTALLER SHALL TAKE FULL RESPONSIBILITY FOR THE SYSTEM.

MAINTENANCE PERIOD:

THE SYSTEM INSTALLER SHALL BE REQUIRED TO PROVIDE SYSTEM INSPECTION AND MAINTENANCE FOR A PERIOD OF 12 MONTHS FROM START-UP. IN THE EVENT THAT THE SYSTEM DOES NOT OPERATE PROPERLY, THE INSTALLER SHALL CONTACT OEPA, THE HEALTH DEPARTMENT AND SYSTEM DESIGNER FOR A FIELD VISIT TO DETERMINE CORRECTIVE ACTIONS.

KRB Engineering, Inc.
Professional Civil Engineering

330 Downing Drive
Chardon, Ohio 44024

Phone: (440) 286 - 7150
Email: kbender1@windstream.net

NOTES & DETAILS

New Four Bedroom Home
S/L 11 Rivers Edge
Willoughby Hills, Lake County
July 2011



2 WORKING DAYS
BEFORE YOU DIG



CALL TOLL FREE 800-362-2764
OHIO UTILITIES PROTECTION SERVICE