

NOTES:
Backflow Preventor Required
For Sanitary Connections.
Cleanouts shall be provided
for sanitary & storm
connections. Cleanouts to
be located @ the back of utility
or drainage easement, respectively.
All Cleanout Risers should be 6"
diameter and have Cast Iron Caps.
Sanitary Connections Shall Be
6" At Minimum 1.0%
Storm Connections Shall Be
6" At Minimum 1.0%
Water Connections To Be 1"



1 inch = 30 ft.

JAMES R. GILLS, P.E.

County Drainage Engineer

By L.S. Date 5/12/09

1 | 1 | 1

 2 WORKING DAYS
BEFORE YOU DIG 
CALL TOLL FREE 800-362-2764
OHIO UTILITIES PROTECTION SERVICE
NON-MEMBERS MUST BE CALLED DIRECT