

GENERAL NOTES

REVIEW OF DRAINAGE FACILITIES (CONT.)

ALL EXISTING SEWERS INSPECTED INITIALLY BY THE ABOVE MENTIONED PARTIES SHALL BE MAINTAINED AND LEFT IN A CONDITION REASONABLY COMPARABLE TO THAT DETERMINED BY THE ORIGINAL INSPECTION. ANY CHANGE IN THE CONDITION RESULTING FROM THE CONTRACTOR'S OPERATIONS SHALL BE CORRECTED BY THE CONTRACTOR TO THE SATISFACTION OF THE ENGINEER.

PAYMENT FOR ALL OPERATIONS DESCRIBED ABOVE SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE PERTINENT 603 CONDUIT ITEMS OF THE CONTRACT.

ITEM 604 - CATCH BASIN NO. 3A, AS PER PLAN

CONCRETE BRICK OR CONCRETE MASONRY BLOCK SHALL NOT BE USED FOR THE CONSTRUCTION OF PROPOSED CATCH BASINS IN THIS PROJECT. OTHERWISE, ALL WORK SHALL CONFORM TO ITEM 604 AND THE DETAIL SHOWN ON SHEET NO. 38.

PAVEMENT

CONTRACTION JOINTS IN BASE WIDENING

WHERE NEW CONCRETE BASE IS PLACED ADJACENT TO EXISTING CONCRETE PAVEMENT, CONTRACTION JOINTS SHALL BE PROVIDED IN THE NEW BASE SO AS TO FORM A CONTINUOUS JOINT WITH THAT IN THE EXISTING PAVEMENT.

THE MAXIMUM DISTANCE BETWEEN THE JOINTS IN NEW BASE SHALL BE IN ACCORDANCE WITH STANDARD CONSTRUCTION DRAWING BP-4. IF NECESSARY, ADDITIONAL JOINTS SHALL BE PROVIDED IN NEW BASE AT APPROXIMATELY EQUAL INTERVALS BETWEEN EXISTING JOINTS THAT EXCEED THE MAXIMUM SPACING.

ITEM 407 - TACK COAT

THE RATE OF APPLICATION OF 407 TACK COAT SHALL BE SUBJECT TO ADJUSTMENT, AS DIRECTED BY THE ENGINEER. PLAN QUANTITIES INDICATE AN AVERAGE APPLICATION RATE OF 0.10 GALLONS PER SQUARE YARD OF TACK COAT FOR ESTIMATING PURPOSES ONLY.

JOINT SEALERS

ALL REFERENCES, HEREIN, TO 705.01 OR 705.02 APPEARING ON STANDARD DRAWINGS OR ON THE PLANS SHALL BE CONSIDERED TO READ 705.04.

ITEM 304 - AGGREGATE BASE, AS PER PLAN

MATERIALS FURNISHED FOR THIS ITEM SHALL EXCLUDE ALL SLAG EXCEPT GRANULATED SLAG OR CRUSHED AIR-COOLED BLAST FURNACE SLAG. THE MAXIMUM TOTAL PERCENT PASSING THE NO. 200 SIEVE FOR 304 SHALL BE 8 PERCENT AS OPPOSED TO THE 13 PERCENT SHOWN IN 304.02.

ITEM 310 - SUBBASE TYPE II, AS PER PLAN

MATERIALS FURNISHED FOR THIS ITEM SHALL EXCLUDE ALL SLAG EXCEPT GRANULATED SLAG OR CRUSHED AIR-COOLED BLAST FURNACE SLAG AND SHALL EXCLUDE THAT PART OF BROKEN SALVAGED PORTLAND CEMENT PAVEMENT PASSING THE NO. 4 SIEVE. BROKEN SALVAGED PORTLAND CEMENT CONCRETE PAVEMENT SHALL BE OBTAINED ON THIS PROJECT OR OTHER PROJECTS CONSTRUCTED UNDER ODOT SPECIFICATIONS. ALL OTHER REQUIREMENTS OF 310 AND 703.04 SHALL APPLY.

ITEM 504. STEEL SHEET PILING LEFT IN PLACE, AS PER PLAN

THE UNIT PRICE BID FOR SQUARE FOOT FOR ITEM 504, STEEL SHEET PILING LEFT IN PLACE, AS PER PLAN SHALL INCLUDE THE COST TO EXCAVATE AROUND THE WALL OF THE TOWER LIGHT MAINTENANCE PLATFORMS LOCATED AT STA. 25+45, RIGHT AND STA. 34+74, RIGHT TO DETERMINE THE LOCATION OF UNDERGROUND ELECTRICAL CONDUIT PRIOR TO INSTALLING THE STEEL SHEET PILING. SEE SHEET 47 FOR DETAILS.

ITEM 802 - BARRIER REFLECTORS

THE FOLLOWING ESTIMATED QUANTITIES HAVE BEEN CARRIED TO THE GENERAL SUMMARY FOR THE PLACEMENT OF BARRIER REFLECTOR ON PROPOSED GUARDRAIL AND BRIDGE PARAPETS:

ITEM 802 - BARRIER REFLECTOR, TYPE A 30 EACH
ITEM 802 - BARRIER REFLECTOR, TYPE B 8 EACH