



- NOTES:**
- For Sections J-J and K-K, See Sheet 7/19.
 - For Plastic Pipe Termination Detail, See Sheet 7/19.
 - Field Bending and/or Cutting of Reinforcing Steel Where Necessary to Place it 2" Clear (Minimum) From the Concrete Face Shall be Incidental in the Price Bid for Item 511-Class C Concrete, Abutment, Not Including Footing, As Per Plan.
 - For Proposed Rock Channel Protection Limits, See Site Plan.
 - Backfill Under the Approach Slab and Sidewalk Between the Porous Backfill and the Existing Abutment Shall Be 203 Granular Material Placed in 6 Inch Lifts and Compacted in Accordance with 304.05. Payment for Furnishing, Placing and Compacting the Granular Backfill Shall Be Included with Item 503-Backfill, As Per Plan (Forward Abutment.)
 - Before Placing the Footing Concrete, Fill All Voids Between the Slope and the Footing Bottom With On Site Material. Place in 6 inch Layers and Compact in Accordance With 304.04. Payment Shall be Included in the Lump Sum Price Bid for Item 503-Unclassified Excavation, As Per Plan.
 - The Existing Reinforced Concrete Pedestal Shall be Removed if It Interferes With the Driving of Piles 11 & 12. Otherwise, It May Remain in Place and Piles 11 & 12 Shall be Driven to Refusal on the Concrete Footing or Bedrock. For Additional Existing Abutment Removal Information, See Item 202 General Note on Sheet 2/19.
 - For Waterstop Location, See Section G-G and Detail X on ODOT Std. Dwg. ICD-1-82, Sheets 3 and 5 of 5. For Preformed Expansion Joint Filler Location, See ODOT Std. Dwg. ICD-1-82, Sheet 3 of 5. Payment for Labor, Materials, and Installation of Waterstop and PEJF Shall be Included in Item 511-Class C Concrete, Abutment, Not Including Footing, As Per Plan.
 - For Forward Abutment Integral Backwall Reinforcing Steel and Superstructure Elevations, See Sheet 12/19.
 - For Reinforcing Steel Bending Diagrams, See ICD-1-82, Sheet 4 of 5.
 - NOTATION: C.J.-Construction Joint; EL.-Elevation; Typ.-Typical; Brg.-Bearing; Sta.-Station; PEJF-Preformed Expansion Joint Filler; E.F.-Each Face; Dia.-Diameter; Fwd.-Forward.

H:\CT\97260\CAD\97260B03.DWG PLOT SCALE 1:32