### Erosion and Sediment Control Schedule

A stone access drive complete with under lying goo-textile fabric (20 feet wide and 50 feet long) for ingress and egress at the site shall be installed. This drive shall be the only entrance and exit to the side

#### Silt Fence

All silt sence shall be installed prior to any earthwork activities at the site in the locations shown on the site plan as well as along the front of any lot that slopes towards the street

Temporary Seeding
Disturbed areas of the site that are to remain idle for more than thirty (30) days shall be properly seeded and straw mulched within seven (7) days of completion of initial grading Temporary seeding and mulching of a thirty (30) foot strip of the entire front of the lot shall be maintained on the site once initial grading is complete

Stabilization of critical areas within fifty (50) feet or any stream or wetland shall be complete within two (2) days of the disturbance if the site is to remain inactive for longer than fourteen (14) days

#### Mulching

Straw-mulch shall be applied at a rate of 1 bale per every ten (10) feet of curb, at a width of thirty (30) feet of the entire length of the lot Wood chips may also be used but must be spread at a minimum depth of four inches over the thirty-foot width and must be accompanied by a properly installed silt


#### !faintenance

Erosion and sediment controls shall be inspected every seven (7) days of within 21 hours of a 0.5" or treater rainfall event Necessary repairs shall be made at this time


All erosion and sediment control specifications, application, and timetables are based of the descriptions and standards of The Ohio Department of Natural Resources "Rainwater and Land Development 'Ianual" and can be found in the Lake County Erosion and Sediment Control Rules as adopted December 21,

The specified erosion and sediment control standards are general hundelines and shall not limit the right of the county to impose. at any time, additional, more stringent requirements. Nor shall the standards limit the right of the county to

## Construction Entrance Detail



## Silt Fence Detail



APPREOVED

# Temporary Seeding Specifications

Species	Lb /1,000 ft 2	Per Ac
Oats	3	4 bushel
Tall Fescue	1	40 lb
Annual Ryegrass	1	10 lb
Perennial Ryegrass	1	40 lb
Tall Fescue	1	40 lb
Annual Ryegrass	1	40 lb
Ryc	3	4 bushel
Tall Fescue	t	10 15
Annual Ryegrass	1	40 16
i7hcat	3	2 brishel
Tall Fescue	1	40 lb
Annual Ryegrass	1	40 lb
Perennial Ryegrass	1	10 lb
Tall Fescue	1	40 lb
Annual Ryegrass	t .	40 lb
	Tall Fescue Annual Ryegrass  Perennial Ryegrass  Tall Fescue Annual Ryegrass  Rye  Tall Fescue Annual Ryegrass  Wheat  Tall Fescue Annual Ryegrass  Perennial Ryegrass  Tall Fescue	Tall Fescue 1 Annual Ryegrass 1  Perennial Ryegrass 1  Tall Fescue 1 Annual Ryegrass 1  Rye 3  Tall Fescue 1 Annual Ryegrass 1  Wheat 3  Tall Fescue 1 Annual Ryegrass 1  Ferennial Ryegrass 1  Perennial Ryegrass 1  Tall Fescue 1 Annual Ryegrass 1