

GENERAL NOTES

FOR GENERAL NOTES, SEE SHEET [1/78] AND [2/78].

PROPOSED WORK

THE WORK PROPOSED FOR THIS STRUCTURE IS COMPRISED OF BUT NOT LIMITED TO THE FOLLOWING:

1. REMOVAL OF THE REINFORCED CONCRETE DECK INCLUDING PARAPETS AND RAILING.
2. REMOVAL OF THE ROADWAY END DAMS.
3. REMOVAL OF THE EXISTING SCUPPERS.
4. REMOVAL AND REPLACEMENT OF THE REAR ABUTMENT BACKWALL.
5. REMOVAL OF WINGWALL PARAPETS.
6. REMOVAL OF THE ASPHALT WEARING SURFACE ON THE FORWARD APPROACH SLAB.
7. INSTALLING STRUCTURAL EXPANSION JOINTS INCLUDING ELASTOMERIC STRIP SEALS.
8. PLACEMENT OF NEW SHEAR STUDS ON BEAMS.
9. CONSTRUCTING A NEW WIDER REINFORCED CONCRETE DECK SLAB WITH NEW SIDEWALKS AND SAFETY PARAPETS WITH CHAINLINK FENCE.
10. CONSTRUCTING NEW CONCRETE PARAPETS WITH CHAINLINK FENCE AND SIDEWALKS ON THE ABUTMENT WINGWALLS.
11. PATCHING DELAMINATED AREAS AT THE ABUTMENTS AND PIERS.
12. SEALING OF DESIGNATED CONCRETE SURFACES.
13. OVERLAY WITH ASPHALT CONCRETE THE EXISTING FORWARD APPROACH SLAB.
14. REMOVAL AND REPLACEMENT OF THE REAR APPROACH SLAB.
15. CONSTRUCTING REINFORCED CONCRETE SIDEWALKS ON THE APPROACH SLABS.

ITEM 202 - PORTIONS OF STRUCTURES REMOVED

THIS ITEM SHALL INCLUDE THE COMPLETE REMOVAL OF THE EXISTING REINFORCED CONCRETE DECK AND PARAPETS, THE COMPLETE REMOVAL OF THE PARAPETS AT THE WINGWALLS, AND THE COMPLETE REMOVAL OF ALL EXPANSION JOINT HARDWARE INCLUDING THOSE PORTIONS OF END DAM GUSSET PLATES AS INDICATED ON SHEET [78/78]. ALSO INCLUDED IS THE COMPLETE REMOVAL OF THE BACKWALL AND APPROACH SLAB AT THE REAR (SOUTH) ABUTMENT AND THE REMOVAL OF THE TOP 1'-3" OF THE BACKWALL AT THE FORWARD (NORTH) ABUTMENT AS INDICATED ON THE ABUTMENT DEMOLITION AND REPAIR DRAWING.

THE FOLLOWING ARE APPROXIMATE QUANTITIES OF MATERIALS TO BE REMOVED UNDER THIS ITEM:

1. SUPERSTRUCTURE CONCRETE (APPROX. 287 CUBIC YARDS)
2. SUBSTRUCTURE CONCRETE (APPROX. 9 CUBIC YARDS)
3. CONCRETE PARAPET (APPROX. 543 LINEAR FEET)

FOR APPROACH SLAB TO BE REMOVED, SEE HIGHWAY DRAWINGS.

EXCAVATION NECESSARY TO REMOVE AND MODIFY PORTIONS OF THE EXISTING STRUCTURE SHALL BE INCLUDED WITH THIS ITEM FOR PAYMENT.

FOR ADDITIONAL NOTES, SEE ITEM 202 - PORTIONS OF STRUCTURES REMOVED ON SHEET [1/78].

ITEM 513 - STRUCTURAL STEEL

THIS ITEM SHALL CONSIST OF FURNISHING, FABRICATING, AND INSTALLING THE STRUCTURAL STEEL CURB PLATES.

NEW STEEL SHALL BE CLEANED AND PRIME PAINTED IN THE FIELD. AT THE CONTRACTOR'S OPTION, NEW STEEL MAY BE GIVEN A PRELIMINARY CLEANING IN THE SHOP. THE COST OF CLEANING AND PRIME PAINTING SHALL BE INCLUDED IN THE UNIT PRICE BID FOR THE SPECIAL ITEMS "FIELD PAINTING OF NEW STRUCTURAL STEEL, SYSTEM OZEU."

ITEM 517 - RAILING (CLASS S CONCRETE PARAPET WITH CHAIN LINK FENCE)

THIS ITEM SHALL INCLUDE THE FURNISHING OF CLASS S CONCRETE PARAPET, THE PARAPET REINFORCEMENT, THE FENCE, ANY OTHER RAILING MATERIALS AND THE NECESSARY LABOR TO CONSTRUCT AND ERECT THE COMPLETED RAILING AS SHOWN ON SHEET [76/78].

ITEM 518 - POROUS BACKFILL, AS PER PLAN

POROUS BACKFILL SHALL BE GRAVEL AND SHALL BE ENCASED WITH FILTER FABRIC TO THE LIMITS SHOWN ON SHEET [75/78]. THE FILTER FABRIC SHALL CONFORM TO ITEM 712.09, TYPE A AND SHALL BE INCLUDED WITH ITEM 518 - POROUS BACKFILL, AS PER PLAN FOR PAYMENT.

ADDITIONAL EXCAVATION (IN EXCESS OF WHAT IS NECESSARY IN ITEM 202 TO REMOVE PORTIONS OF THE EXISTING STRUCTURE) REQUIRED TO REPLACE POROUS BACKFILL BEHIND THE REAR ABUTMENT SHALL BE INCLUDED IN ITEM 518 - POROUS BACKFILL, AS PER PLAN FOR PAYMENT.

REPAIR OF EXISTING CONCRETE

ITEM 520 - PNEUMATICALLY PLACED MORTAR SHALL BE USED AS DIRECTED BY THE ENGINEER AND AS OUTLINED ON THE ABUTMENT DEMOLITION AND REPAIR DRAWING TO REPAIR DAMAGED CONCRETE AREAS. ALL SURFACES TO BE PATCHED AND THE EXPOSED REINFORCING STEEL WITHIN, SHALL BE THOROUGHLY CLEANED BY ABRASIVE BLASTING PRIOR TO THE CLEANING SPECIFIED BY 519.04 AND 520.05. CLEANING SHALL PRECEDE APPLICATION OF THE PATCHING MATERIAL BY NOT MORE THAN 24 HOURS.

ITEM 601 - CRUSHED AGGREGATE SLOPE PROTECTION

THIS WORK SHALL INCLUDE REMOVAL OF EXISTING SLOPE PROTECTION MATERIAL AND EXCAVATION OF ANY MATERIAL NECESSARY TO ACHIEVE A 12" MINIMUM CRUSHED AGGREGATE SLOPE PROTECTION DEPTH. ALSO INCLUDED IS THE PLACEMENT OF EMBANKMENT MATERIAL, COMPACTED IN ACCORDANCE WITH ITEM 203, TO FILL ERODED AREAS AND THE PLACEMENT OF NEW CRUSHED AGGREGATE SLOPE PROTECTION AS INDICATED IN PROJECT PLANS.

ALL COSTS FOR THE REMOVAL OF EXISTING SLOPE PROTECTION MATERIAL, EXCAVATION, EMBANKMENT, AND PLACEMENT OF CRUSHED AGGREGATE SLOPE PROTECTION SHALL BE INCLUDED UNDER THE CONTRACT BID PRICE PER SQUARE YARD, ITEM 601 - CRUSHED AGGREGATE SLOPE PROTECTION.

FIELD PAINTING OF NEW STRUCTURAL STEEL, SYSTEM OZEU

THIS WORK SHALL CONSIST OF SUPPLYING THE MATERIALS, LABOR, AND EQUIPMENT NECESSARY FOR THE CLEANING AND FIELD PAINTING OF THOSE PORTIONS OF THE CURB PLATES NOT FULLY ENCASED IN CONCRETE AND THOSE PORTIONS OF THE EXPANSION JOINT HARDWARE NOT FULLY ENCASED IN CONCRETE INCLUDING THE NEW GUSSET SPlice PLATES DETAILED ON SHEET [78/78]. ALSO INCLUDED FOR PAYMENT UNDER THIS ITEM IS TOUCH-UP PAINTING OF EXISTING STEEL REQUIRED AS A DIRECT RESULT OF THE INSTALLATION OF ANY NEW STEEL.

NEW STEEL SHALL BE PROVIDED BARE FOR PREPARATION AND PAINTING IN THE FIELD. FOR PURPOSES OF FIELD PAINTING, NEWLY ERECTED STEEL SHALL BE CONSIDERED EXISTING STEEL AND SHALL BE PREPARED AND PAINTED WITH A PRIME, INTERMEDIATE AND FINISH COAT OF PAINT IN CONFORMANCE WITH THE PROPOSAL NOTE "FIELD PAINTING OF EXISTING STEEL, SYSTEM OZEU." COST OF CLEANING AND PAINTING OF NEW STEEL WITH THE OZEU PAINT SYSTEM SHALL BE INCLUDED IN SPECIAL ITEMS "FIELD PAINTING OF NEW STRUCTURAL STEEL, SYSTEM OZEU." AT THE CONTRACTOR'S OPTION, NEW STEEL MAY BE GIVEN A PRELIMINARY CLEANING IN THE SHOP.

APPROACH SLAB REPLACEMENT

ALL MATERIALS (INCLUDING BUT NOT LIMITED TO CLASS C CONCRETE, REINFORCING STEEL, AND PREFORMED EXPANSION JOINT FILLER WITH JOINT SEALER) AND LABOR REQUIRED IN THE REPLACEMENT OF THE REAR (SOUTH) APPROACH SLAB AS INDICATED IN DETAILS ON SHEET [72/78] OF THE BRIDGE PLANS, SHALL BE INCLUDED FOR PAYMENT IN THE PRICE BID PER SQUARE YARD FOR ITEM 611 IN THE ROADWAY QUANTITIES.

SIDEWALKS ON APPROACH SLABS

ALL MATERIALS (INCLUDING BUT NOT LIMITED TO CLASS S CONCRETE, REINFORCING STEEL, AND DOWELS) AND LABOR REQUIRED IN CONSTRUCTING SIDEWALKS ON APPROACH SLABS AS INDICATED IN DETAILS ON SHEET [72/78] AND [73/78] OF THE BRIDGE PLANS, SHALL BE INCLUDED FOR PAYMENT IN THE PRICE BID PER SQUARE FOOT FOR ITEM 608 IN THE ROADWAY QUANTITIES.

ESTIMATED QUANTITIES FOR LAK-2-1029

ITEM	ITEM EXT.	TOTAL	UNIT	DESCRIPTION	ABUT.	PIERS	SUPER.	GENERAL
202	11200	LUMP		Portions of Structure Removed	—	—	—	LUMP
509	11400	200	lb.	Reinforcing Steel, Grade 60	—	—	—	200
509	15800	84,511	lb.	Epoxy Coated Reinforcing Steel, Grade 60	2,979	—	81,532	—
510	11100	102	EACH	Dowel Holes	102	—	—	—
511	34401	359	CU. YD.	Class S Concrete, Superstructure, as per Plan (SEE SH. 36)	—	—	359	—
511	45700	25	CU. YD.	Class C Concrete, Abutments	25	—	—	—
512	33300	10	SQ. YD.	Type A Waterproofing	10	—	—	—
513	11100	7,699	lb.	Structural Steel (AISC Category I) (See Proposal Note)	—	—	7,699	—
513	20000	3,780	EACH	Welded Stud Shear Connectors	—	—	3,780	—
516	11200	79	LIN. FT.	Structural Expansion Joints Including Elastomeric Strip Seals	—	—	79	—
517	75300	540	LIN. FT.	Railing (Class S Concrete Parapet With Chainlink Fence)	—	—	540	—
518	21101	9	CU. YD.	Porous Backfill, as per plan	9	—	—	—
520	11100	380	SQ. FT.	Pneumatically Placed Mortar (See Proposal Note)	206	174	—	—
601	20000	421	SQ. YD.	Crushed Aggregate Slope Protection	421	—	—	—
SPECIAL	512 67500	833	SQ. YD.	Sealing of Concrete Surfaces (See Proposal Note)	89	—	744	—
SPECIAL	512 67504	301	SQ. YD.	Sealing of Concrete Surfaces (Non-Epoxy) (See Proposal Note)	—	301	—	—
SPECIAL	512 67502	59	SQ. YD.	Sealing of Concrete Surfaces (Epoxy) (See Proposal Note)	59	—	—	—
SPECIAL	514 00410	LUMP		Field Painting of New Structural Steel, Surface Preparation, System OZEU	—	—	—	LUMP
SPECIAL	514 00420	LUMP		Field Painting of New Structural Steel, Prime Coat, System OZEU	—	—	—	LUMP
SPECIAL	514 00430	LUMP		Field Painting of New Structural Steel, Intermediate Coat, System OZEU	—	—	—	LUMP
SPECIAL	514 00440	LUMP		Field Painting of New Structural Steel, Finish Coat, System OZEU	—	—	—	LUMP

COLPETZER-THOMAS, INC.
AN ENGINEERING GROUP
WILLOUGHBY • MENTOR • NORTH CANTON • STEUBENVILLE • LORAIN

NOTES AND ESTIMATED QUANTITIES
BRIDGE NO. LAK-2-1029
S.R.2 UNDER MUNSON ROAD
LAKE COUNTY

DESIGNED	DRAWN	TRACED	CHECKED	REVIEWED	DATE	REVISED
B.J.A.	J.L.J.	J.L.J.	R.J.C.	J.E.A.	11/15/88	