

**Proposal Addendum
For
LAK-2-3.32; PID 13486
Project 080597**

Revised Bid Items:

Ref. No.	Item Number	Quantity	Unit	Description
9	202E35100	13402	FT	Pipe Removed, 24" and Under
10	202E35200	1013	FT	Pipe Removed, Over 24"
141	605E11110	100354	FT	6" Shallow Pipe Underdrains With Fabric Wrap
143	605E14020	100478	FT	6" Base Pipe Underdrains With Fabric Wrap
630	513E10281	255271	LB	Structural Steel Members, Level 4, As Per Plan
671	513E10281	255548	LB	Structural Steel Members, Level 4, As Per Plan
712	513E10240	230201	LB	Structural Steel Members, Level 2
743	513E10240	185934	LB	Structural Steel Members, Level 2
89	603E05900	3269	FT	15" Conduit, Type B
90	603E06100	2034	FT	15" Conduit, Type C
1034	888E14060	394559	SY AA2	Portland Cement Concrete Pavement, 11.52" Thick (Non-Reinforced Per 452)

Revise Sheet:

Revise typical sections to depict Shallow Pipe Underdrains (30" Deep Typ.) for all of SR-91 and SR-306 Ramps, while SR-91 and SR-306 side roads should depict Base Pipe Underdrains, unless called out in the tables to utilize unclassified underdrains.

Revise the note, on sheet 967/1679, that is titled Wall, Material and Color to delete any reference to motor joint color. This project will not utilize a separate motor joint color. The entire brick panel (highway and resident side), with the exception of the icons, posts and caps, shall be Federal Color #595B-20109 red brick in color. The brick formliner brick size shall be 2 2/3" x 8" for the highway and resident side.

Add the following supplemental specification:

888 Portland Cement Concrete Pavement QC/QA Dated 04/18/08

All reference to Item 452 – 11.5" Non-Reinforced Concrete Pavement within the Bid Documents shall be revised to read Item 888 – Portland Cement Concrete Pavement, 11.5" Thick (Non-Reinforced per 452). Supplemental Specification 888 Portland Cement Concrete Pavement QC/QA applies to the mainline and ramp concrete pavement, for the concrete alternative only. CMS 451 or 452 shall apply to side road concrete pavement as detailed in the plans.

PN 420 applies only to Asphalt Concrete Pavement.