

# Asbestos Identification by Polarized Light Microscopy

## Analysis Report



200 Prestige Park  
Hurricane, West Virginia  
26526  
Phone: 304-757-5204  
Fax: 304-757-5205

NVLAP LAB CODE: 200718-0

License #: LT000303

Attn: Leon Bell  
Ohio Dept. of Transportation  
2088 South Arlington Street  
Akron, OH 44306

Received Date: 3/24/2008  
Analysis Date: 3/24/2008

PEC Project #:  
Client Project/PO #: PID 13486

RE: Parcel 9 - 36628 Vine Street, East Lake, OH

PEC LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07099	LAK2PCL9#1	Basement Ceiling (Acoustic)	Tan/White
Texture/Description: Fibrous/Ceiling Panels			
Chrysotile: 0% Tremolite: 0% Anthophyllite: 0%			
TOTAL ASBESTOS: 0%			
Amosite: 0% Actinolite: 0% Crocidolite: 0%			
Cellulose: 88% Fiber Glass: 0% Others: 0% Filler/Binder: 12%			

PEC LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07100a	LAK2PCL9#2	Basement Stairway Ceiling	Grey
Texture/Description: Solid/Plaster			
Chrysotile: 2% Tremolite: 0% Anthophyllite: 0%			
TOTAL ASBESTOS: 2%			
Amosite: 0% Actinolite: 0% Crocidolite: 0%			
Cellulose: 0% Fiber Glass: 0% Others: 3% Filler/Binder: 95%			

PEC LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07100b	LAK2PCL9#2	Basement Stairway Ceiling	White
Texture/Description: Solid/Top Coat			
Chrysotile: 0% Tremolite: 0% Anthophyllite: 0%			
TOTAL ASBESTOS: 0%			
Amosite: 0% Actinolite: 0% Crocidolite: 0%			
Cellulose: 0% Fiber Glass: 0% Others: 0% Filler/Binder: 100%			

PEC LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07101	LAK2PCL9#3	Basement Stairway Wall	Beige/Tan
Texture/Description: Solid/Plasterboard			
Chrysotile: 0% Tremolite: 0% Anthophyllite: 0%			
TOTAL ASBESTOS: 0%			
Amosite: 0% Actinolite: 0% Crocidolite: 0%			
Cellulose: 10% Fiber Glass: 0% Others: 0% Filler/Binder: 90%			

PEC LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07102	LAK2PCL9#4	1st Fir S Office Wall Center	Cream
Texture/Description: Solid/Plasterboard Joint			
Chrysotile: 0% Tremolite: 0% Anthophyllite: 0%			
TOTAL ASBESTOS: 0%			
Amosite: 0% Actinolite: 0% Crocidolite: 0%			
Cellulose: 0% Fiber Glass: 0% Others: 0% Filler/Binder: 100%			