

RE: Parcel 9 - 36628 Vine Street, East Lake, OH

REG LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07112b	LAK2PCL9#14	2nd Fir Hallway Ceiling	White
Texture/Description:	Solid/Top Coat	Chrysotile: 0%	Tremolite: 0% Anthophyllite: 0%
TOTAL ASBESTOS:	0%	Amosite: 0%	Actinolite: 0% Crocidolite: 0%
Cellulose: 0%	Fiber Glass: 0%	Others: 0%	Filler/Binder: 100%

REG LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07113	LAK2PCL9#15	2nd Fir N Office Wall	Bge/Tan/Crm
Texture/Description:	Solid/Plasterboard	Chrysotile: 2%	Tremolite: 0% Anthophyllite: 0%
TOTAL ASBESTOS:	2%	Amosite: 0%	Actinolite: 0% Crocidolite: 0%
Cellulose: 13%	Fiber Glass: 0%	Others: 0%	Filler/Binder: 85%

REG LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07114	LAK2PCL9#16	2nd Fir Rear Office Wall	Beige/Tan
Texture/Description:	Solid/Plasterboard	Chrysotile: 0%	Tremolite: 0% Anthophyllite: 0%
TOTAL ASBESTOS:	0%	Amosite: 0%	Actinolite: 0% Crocidolite: 0%
Cellulose: 8%	Fiber Glass: 0%	Others: 0%	Filler/Binder: 92%

REG LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07115	LAK2PCL9#17	2nd Fir Window	Grey
Texture/Description:	Solid/Glaze	Chrysotile: 3%	Tremolite: 0% Anthophyllite: 0%
TOTAL ASBESTOS:	3%	Amosite: 0%	Actinolite: 0% Crocidolite: 0%
Cellulose: 0%	Fiber Glass: 0%	Others: 0%	Filler/Binder: 97%

REG LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07116	LAK2PCL9#18	House Roof	Black/Brown
Texture/Description:	Solid/Asphalt Shingle	Chrysotile: 0%	Tremolite: 0% Anthophyllite: 0%
TOTAL ASBESTOS:	0%	Amosite: 0%	Actinolite: 0% Crocidolite: 0%
Cellulose: 0%	Fiber Glass: 0%	Others: 9%	Filler/Binder: 91%

REG LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07117	LAK2PCL9#19	1st Fir Front Office Front Wall Corner	Cream
Texture/Description:	Solid/Plasterboard Joint	Chrysotile: 2%	Tremolite: 0% Anthophyllite: 0%
TOTAL ASBESTOS:	2%	Amosite: 0%	Actinolite: 0% Crocidolite: 0%
Cellulose: 0%	Fiber Glass: 0%	Others: 0%	Filler/Binder: 98%

REG LAB #	CLIENT ID #	LOCATION	COLOR
08WB-07118	LAK2PCL9#20	2nd Fir S Office Corner Joint	Cream
Texture/Description:	Solid/Plasterboard Joint	Chrysotile: 3%	Tremolite: 0% Anthophyllite: 0%
TOTAL ASBESTOS:	3%	Amosite: 0%	Actinolite: 0% Crocidolite: 0%
Cellulose: 0%	Fiber Glass: 0%	Others: 0%	Filler/Binder: 97%