

Asbestos Identification by Polarized Light Microscopy

Point Count Analysis Report



200 Prestige Park
Hurricane, West Virginia
25528
Phone: 304-757-5204
Fax: 304-757-5205

NVLAP LAB CODE: 200718.0

License #: LT000306

Attn: Leon Bell
Ohio Dept. of Transportation
2088 South Arlington Street
Akron, OH 44306

Received Date: 3/24/2008
Analysis Date: 3/26/2008

PEC Project #:
Client Project #: PID 13486

RE: Parcel 9 - 36628 Vine Street, East Lake, OH

CLIENT ID	PEC LAB	PLM ANALYSIS		POINT COUNT ANALYSIS	
		% Asbestos	Type	% Asbestos	Type
LAK2PCL9#2	08WB-07100a	2 %	Chrysotile	0.50 %	Chrysotile
LAK2PCL9#6	08WB-07104	3 %	Chrysotile	0.75 %	Chrysotile
LAK2PCL9#7	08WB-07105	2 %	Chrysotile	0.75 %	Chrysotile
LAK2PCL9#9	08WB-07107a	3 %	Chrysotile	0.50 %	Chrysotile
LAK2PCL9#13	08WB-07111a	2 %	Chrysotile	0.25 %	Chrysotile
LAK2PCL9#14	08WB-07112a	2 %	Chrysotile	0.50 %	Chrysotile
LAK2PCL9#15	08WB-07113	2 %	Chrysotile	Trace	Chrysotile