

THE C.E.I. CO. FILE NR-11556912 DATE 6/4/08 SHEET 3 OF 4
 BEFORE YOU DIG "IT'S THE LAW" CALL TOLL FREE 800-362-2764 OHIO UTILITIES PROTECTION SERVICE
 2 WORKING DAYS
 L-4-MB-L 13.2KV
 ORDER #123102B2
 WBS# CN-000795

STATE OF OHIO
 LAKELAND BLVD @ VINE ST
 WILLOUGHBY
 SHIFT FOR ROAD IMP.
 WERNER & WERNER ENGINEERING

JOINT PROPOSAL JP#392445
 J.O. B.J.O.

DATE	J.P.	FOR-EST	D.H.	CHRG	SERV	MRKT.	REC.	ENR	EST	LD	WTR	TOTL
6/4/08		S					2	2	1	1	1	17

CONSTRUCTION HISTORY

DATE	DESCRIPTION	APPROVED BY

UNDERGROUND FACILITIES WARNING
 HIGH PRESSURE PIPELINE _____ FT. CHECKED BY _____
 TELEPHONE _____

O. H. TRANSMISSION CLEARANCE WARNING
 _____ FT. MIN. CLEARANCE REQUIRED AT _____ DEGREES F.
 AT SYMBOLS _____

ENGINEERING CHECKED BY: _____ DATE: _____
 CONSTRUCTION CHECKED BY: _____ DATE: _____

MAXIMUM RMS SYMMETRICAL FAULT CURRENT AVAILABLE AT SERVICE ENTRANCE IS _____ AMPS., 3PHASE, _____ VOLTS
 _____ AMPS., 1PHASE, _____ VOLTS
 CEI CONTRIBUTION ONLY.

THE CUSTOMER SHALL PROVIDE THE GROUNDING ELECTRODE CONDUCTOR AND GROUNDING ELECTRODE TO THE SERVICE ENTRANCE LOCATION.

BETWEEN (115) & (119) REMOVE #4 TRIP, SEC. (447')
 " " (115) & (119) INSTALL #4 TRIP, SEC. (466')

(117) P#643623 (NEW DEP-114)
 REM-35'5" FULL '66
 SET-35'5" (2'E 7'N.)
 STA-32+63, 40'RT
 REM-R6-13
 " - 8' LAMP BRKT.
 " - 1" ANC GUY
 " - ANCHOR 10'LD S.
 INST-R6-13
 " - 12' LAMP BRKT.
 TRANS. 400W HPS LUMIN.
 INST-1-5/16" ANC GUY
 " - 10" EXP. ANCHOR
 5'LD. EAST
 NO CATV
 NO TEL
 MCH 20'

(119) P#643621
 EX-35'5" FULL '66
 STA-29+34, 19'RT OK
 EX-R6-13
 " - 8' LAMP BRKT
 " - LUMINAIRE
 " - ANC GUY
 " - ANCHOR 10'LD S.
 NO CATV
 NO TEL.

(118) P#643622
 REM-35'5" FULL '76
 SET-35'5" (44'S.E.)
 STA-31+07, 30'RT.
 REM-R6-13
 " - 8' LAMP BRKT.
 INST-R6-13
 " - 16' LAMP BRKT
 TRANS. 400W MBR. LUMIN.
 INST-1-3/8" ANC GUY
 " - 10" EXP. ANCHOR
 12'LD. SE.
 NO CATV
 NO TEL
 MCH 20'

(120) P#711380
 EX-50'3" FULL '07
 STA-27+61, 29'RT OK
 EX-10'OX N5+W.
 " - R6-13

